

Blatt Rachel

From: Kevin Kowalski <KKowalski@simsburyfd.org>
Sent: Monday, November 24, 2014 2:20 PM
To: Blatt Rachel
Subject: RE: Talcott Mtn Estates

Categories: P-Talcott Mtn Estates Subdivision

Rachel ,that is an acceptable plan. As a side note that will be a NFPA 13D system which is designed for a single family home , far less costly .

Thanks for your assistance on this.

From: Blatt Rachel [<mailto:rblatt@simsbury-ct.gov>]
Sent: Monday, November 24, 2014 1:22 PM
To: Kevin Kowalski
Subject: Talcott Mtn Estates

Good afternoon,

Can you confirm for me that the Fire Department would accept the proposed private road with 18 ft. of pavement subject to the following conditions:

- Sprinklers to be installed in the proposed residences
- 12-13 ft. pavement width at the end of driveways #2 and #3 be provided to accommodate fire vehicle turns.

Thank you.

-Rachel

Rachel Blatt
Assistant Town Planner
Town of Simsbury, CT
860-658-3240
rblatt@simsbury-ct.gov